



NOTES:

1. * Check the Acceptability Tables for utility requirements.
2. The AC Disconnect Switch may be fused or unfused.
3. The AC Disconnect Switch shall be located within 10' of the main service panel and within line of sight.
4. A minimum 10" clearance is required from the edge of any enclosure.

ALL DIMENSIONS SHOWN ARE IN INCHES

| REV. | DATE | DESCRIPTION |
|-----------------|-------|---|
| | 11/12 | NEW DRAWING - PROJECT #12-05-07 |
| SCALE N.T.S. | | AC DISCONNECT GUIDELINES |
| DATE 11/12 | | ELECTRIC UTILITY SERVICE EQUIPMENT REQUIREMENTS COMMITTEE |
| | | SHT 1 OF 1 |
| | | DWG NO. 501 REV. |